CBD Infrastructure Improvements CITY OF NEVADA, IOWA

CONTRACTOR'S BID DATE:

Wednesday, February 19, 2020 - 1:00 P.M.

PLACE TO FILE FOR CONTRACTOR'S BIDS:

Office of the City Clerk

1209 6th Street

Nevada, Iowa 50201

ADDENDUM NO. 1

February 18, 2020

TO ALL PLANHOLDERS:

The following changes, additions, and/or deletions are hereby made a part of the Contract Documents for the above referenced project, as fully and completely as if the same were fully set forth therein. All Bidders submitting a Bid on the above Contract shall carefully read this Addendum and give it consideration in the preparation of their Bid.

DRAWINGS:

1. SHEET C.02 -

Item 31-33. Water Main, Trenched, Ductile Iron. Change Note 3:

- From: FKM (Viton) gaskets required.....
- To: Nitrile gaskets required.....

2. SHEET C.02 -

Item 31-33. Water Main, Trenched, Ductile Iron. Add Note 10:

• 10. Restrained joint piping shall utilize a locking ring or similar field-removable system. No external harness or restrained gaskets will be accepted.

3. SHEET C.03 -

Item 35, Description. Change bid item description:

- From: Water Service Stub, 1-1/2" PVC SDR9
- To: Water Service Stub, 1-1/2" PE Class 250, SDR 9, according to AWWA C901

4. SHEET C.03 -

Item 35. Water Service Stub. Change Note 7:

- From: Utilize flared connections
- To: Utilize compression connections with stainless steel insert

5. SHEET C.03 -

Item 36, Description. Change bid item description:

- From: Water Service Stub, 1-1/2" PVC SDR9
- To: Water Service Stub, 1-1/2" PE Class 250, SDR 9, according to AWWA C901

6. SHEET C.03 -

Item 41. Fire Hydrant Assembly. Add Note 8:

• 8. Hydrant shall be provided with Storz pumper nozzle.

All bidders shall acknowledge receipt and acceptance of ADDENDUM NO. 1 by signing the space provided on the Bid Form.

